



REQUEST FOR QUOTE ADDENDUM 1

Released September 18, 2023

Project Name: Fort Greely AHA Material Delivery

Project #: 23-2-5802

Questions

All questions regarding this Addendum must be submitted via email only
rfp@salchadeltaswcd.org and received by:

Monday, September 25, 2023 @ 10:00 am

Questions submitted after that time will not be acknowledged.
It is the contractor's responsibility to check for Addendum prior to submitting a proposal.

All submitted questions will be answered through an Addendum released via email and at
rfp@salchadeltaswcd.org on the following dates:

Question 1: What if the DNR pit that we are looking at to produce rock in is already being operated in by another contractor?

Answer 1: We cannot answer this question until the material sale application has been completed.

Question 2: Will the haul route to the stockpile location be such that the main Ft. Greely Gate can be avoided? Or does the contractor have to get badge clearances for employees, equipment inspection etc.?

Answer 2: Contractor's employees will all need to access Fort Greely. The SDSWCD will help coordinate access.

Question 3: In regard to utilizing a DNR pit, will the SWCD be able to permit a DNR pit by 10/15/2023?

Answer 3: It could take as much as 30 days from the date the application is submitted. The permit will be submitted once the SDSWCD has accepted a quote.

Question 4: When will the contract award take place?

Answer 4: The SDSWCD intends to accept a quote on September 28, 2023.

The Salcha-Delta SWCD prohibits discrimination in all its programs on the basis of race, color, national origin, gender, religion, age, disability, political beliefs, sexual orientation and marital or familial status.

QUOTE SHEET (Addended 9-18-2023)

Quote Due: Thursday, September 28, 2023 at 10:00 am

Project Name: Fort Greely AHA Material Supply & Delivery

Project Number: 23-2-5802

Contractor Company: _____

Representative Name: _____

Contact Phone number: _____

Description of proposed pit location (location, ownership):

Item Description	Total Price
Rock as specified in Table 1 (below)	\$

Table 1: Material Requirements				
Item Description	Quantity	Unit	Unit Cost	Total
Class IV 50-100% weighing 2000 pounds or more 0-15% weighing up to 400 pounds 0-10% weighing more than 5400 pounds	400	Cubic yards		
Class III 50-100% weighing 700 pounds or more 0-15% weighing up to 25 pounds 0-10% weighing more than 1400 pounds	2500	Cubic yards		
Class II 50-100% weighing 200 pounds or more 0-15% weighing up to 25 pounds 0-10% weighing more than 400 pounds	1000	Cubic yards		
Class I Rock Riprap 0-50% weighing up to 25 pounds 0-10% weighing more than 50 pounds	500	Cubic yards		
Rock shall be angular, not round, and have no more than 50% wear at 500 revolutions as determined by AASHTO T96.				

Addendum 1 Received: _____(initial)

Addendum 2 Received: _____(initial)

Submitted by: _____

Date: _____